

	<b>UNION CENTER FIRE COMPANY INC.</b> <b>Best Operating Guidelines</b>	
	<b>Subject: Water Supply – Tanker Ops</b>	<b>BOG Series Operations</b>
		<b>Initiated 01/01/04</b>
<b>Approved: Fire Chief Chris Hoyt</b>	<b>Revised 03/02/13</b>	

When an incident occurs within a non-hydrant district, the first arriving Engine needs a water source. The first due tanker may act as a nurse to the Engine, using either a 4” supply line or a 3” hose line. Once the supply line is established, the “portable pond” may be placed in position for the Engine to draft, if conditions are favorable.

If the incident is off the roadway, the second due engine may establish water supply, and supply first due Engine. Second due Engine, may draft from portable pond, Tankers will dump into the pond.